



Vertical Heights & Hardware Fixings

Crucial for passing the final building audit inspection.

Toilet Pan Heights

- [] Standard/General use pans are set between **390mm – 420mm**.
- [] Ambulant and Accessible pans are set between **460mm – 480mm**.

The "Ambulant Update" Fixings

- [] Mandatory Coat Hooks: Installed in all Ambulant and Accessible cubicles (not optional).
- [] Hook Height: Positioned strictly between **1350mm and 1500mm** above the finished floor level (AFFL).

Safety Rails & Disposables

- [] Grab Rails: Installed at a height of 800mm – 810mm AFFL.
- [] Grab Rail Strength: Fixed to safely withstand a force of 1100N (if using 13mm compact laminate, verify fixings meet this high-load requirement without internal wall noggings).
- [] Toilet Roll Holders: Positioned no higher than 700mm AFFL.